



## BAScontrol22 – 22-point BACnet/IP Sedona Unitary Controller

The BAScontrol22 is a 22-point unitary controller which supports BACnet/IP and Sedona Framework using a 2-port Ethernet switch connection. The controller complies with the B-ASC device profile having a convenient mix of 8 universal inputs, 4 binary inputs, 4 analog outputs and 6 relay outputs. Unique to the unit are 48 web components which link Sedona wire sheet readable/writeable data to web pages, and 24 virtual points which link Sedona wire sheet readable/writeable data to a BACnet client. The device is fully web page-configurable, and freely programmable using Sedona’s drag-and-drop


programming methodology of assembling components onto a wire sheet to create applications. The unit can be programmed using Niagara Workbench AX or a third-party Sedona programming tool such as Sedona Application Editor (SAE). Rugged design, low profile, and wide temperature operation make it suitable for indoor or outdoor use. To download the free Sedona Application Editor, visit: [www.ccontrols.com/sae](http://www.ccontrols.com/sae). For more information about Sedona, SAE, kits, components and programming download the Sedona Reference Manual at: [www.ccontrols.com/sedona](http://www.ccontrols.com/sedona)

### Versatile Control Device — unitary controller or remote Ethernet I/O

- BACnet/IP compliant with a B-ASC device profile
- Resident Sedona Virtual Machine (SVM)
- Programmable via Workbench AX or Sedona Editor
- Configurable with a common web browser
- Direct connection to Ethernet network
- NTP or manually-settable real-time clock
- COV subscriptions – 14 binary and 2 analog
- Outdoor temperature operation -40°C to +75°C

### Flexible Input/Output — 22-points of physical I/O

- Eight configurable universal inputs:
  - Thermistor, resistance, analog voltage, binary input, pulse inputs (4 max)
- Four contact closure inputs
- Four analog voltage outputs
- Six relay outputs



BASC22-R has six relay outputs

**BASautomation® Sedona**

## BAScontrol22 — Overview

The BAScontrol22 utilizes a powerful 32-bit ARM7 processor with 512 kB of flash memory plus a 16 Mbit serial flash file system for storing configuration data and an application program.


By operating at the BACnet/IP level, the BAScontrol22 can share the same Ethernet network with supervisory controllers and operator workstations. The unit can be configured for a fixed IP address or can operate as a DHCP client receiving its IP address from a DHCP server. A real-time clock with a super-cap backup allows for creating local schedules.

Via a 10/100 Mbps Ethernet switch, the Ethernet port supports protocols such as BACnet/IP, Sedona SOX, HTTP and FTP. Configuration of universal inputs and virtual points can be accomplished using web pages. Type II and type III 10 kΩ thermistor curves and a 20 kΩ thermistor curve are resident in the unit. Current inputs can be measured using external resistors. Contact closures require a voltage-free source. Binary inputs and outputs as well as analog outputs require no configuration. The unit is powered from either a 24VAC/VDC source.

### Universal Inputs

Eight input points can be configured — all discoverable as BACnet objects.

- Analog inputs: 0–10 VDC, 12-bit resolution, 0–20 mA (with external resistor)
- Temperature inputs: Type II or Type III 10 kΩ thermistors; 20 kΩ thermistor
- Resistance inputs: 1 kΩ to 100 kΩ
- Contact closure, voltage-free
- Pulse input accumulators (UI1–UI4): accommodates active or passive sources (40 Hz max)



## Web Page Configuration — Main Page and System

Access to the web pages is intended for the installer or skilled technicians. In order to access any of the web pages authentication is required. The default IP address is 192.68.92.68 and the default User Name and Password is admin/admin. Once on the main page, the System Configuration button can be clicked.

The main web page provides an overview of all real points plus access to other web pages. To configure a

point, click on the point and a configuration page will appear. To observe the updated data for each point, click Auto Refresh button to ON. Point values can be temporarily forced by checking the box adjacent to the point and entering a value into the point's text box (make sure Auto Refresh button is OFF). The value will remain forced until the box is unchecked or the unit power cycled. Care must be exercised when forcing values into points.

**Universal Inputs**

UI1	Space Temperature	74.767°F	UI5	Universal Input 5	0.001
UI2	Universal Input 2	0.009	UI6	Universal Input 6	0.001
UI3	Universal Input 3	0.000	UI7	Universal Input 7	0.000
UI4	Universal Input 4	0.000	UI8	Universal Input 8	0.000

**Binary Inputs**

BI1	Binary Input 1	0
BI2	Binary Input 2	0
BI3	Binary Input 3	0
BI4	Binary Input 4	0

**Analog Outputs**

AO1	Damper Control	4.888
AO2	Analog Output 2	5.250
AO3	Analog Output 3	0.000
AO4	Analog Output 4	7.500

**Binary Outputs**

BO1	Binary Output 1	1
BO2	Binary Output 2	0
BO3	Binary Output 3	1
BO4	Binary Output 4	1
BO5	Binary Output 5	1
BO6	Binary Output 6	1

**BAScontrol22**

System Config   System Status   Set Time   Virtual Points   Web Components   Restart Controller

Auto Refresh OFF

Copyright 2017 Contemporary Control Systems, Inc. All rights reserved.  
Firmware Revision 3.1 : Web Page Revision 6.1.4  
NOTE: A GREEN label indicates that the I/O point has been placed on the wire sheet.

The IP settings can be changed to the desired values. Either DHCP or a static IP address can be selected. If a static address is desired, enter the value along with the network mask and gateway address. If domain address is required, enter in the Primary and Secondary DNS addresses.

BACnet device data must be entered when using BACnet. Make sure the Device Instance and Device Object Name are both unique over the complete BACnet Internetwork.

Either BACnet or Sedona protocols or both can be selected.

**IP Configuration**

IP Mode: Static IP

IP Address: 10.0.13.10

Netmask: 255.255.240.0

Gateway: 10.0.0.1

Primary DNS: 8.8.8.8

Secondary DNS: 8.8.4.4

**BACnet Device Configuration**

Device Object Name: BAScontrol22

Device Instance: 21310

UDP Port: 47808

BBMD IP Address: 0.0.0.0

BBMD Reg Time: 100

**Enable Protocol**

BACnet/IP

Sedona

FTP

**Authentication**

User Name: admin

Password: .....

Close   Submit

NOTE: You must click the Submit button to store any changes.  
Changes will not take effect until the controller has been restarted. You can restart the controller from the main page.



## Web Page Configuration — Channel, Time and Web Components

### BAS Channel Configuration

Channel Type  U11

Temperature Offset

Temperature Units  Out of Bounds Value

---

### BACnet Object Configuration

Object Instance

Object Name

Object Type

Object Description

Units

COV Increment

### System Time

Year

Month

Day

Hour

Minute

### NTP Configuration

NTP Enabled

NTP Server

Time Zone

NTP Refresh (Days)

NTP Success

---

### DST Configuration

DST Enabled

	DST ON	DST OFF
Month	<input style="width: 50px;" type="text" value="March"/>	<input style="width: 50px;" type="text" value="November"/>
Day of Month	<input style="width: 50px;" type="text" value="2nd SUN"/>	<input style="width: 50px;" type="text" value="1st SUN"/>
Hour	<input style="width: 50px;" type="text" value="2 AM"/>	<input style="width: 50px;" type="text" value="2 AM"/>

The BAS Channel should be configured first. Universal inputs must first be defined which may lead to more requests for information. Once the BAS Channel is configured, the BACnet Object Configuration can be accomplished. Although the BACnet Object Instance is predefined, the Object Name can be entered and Units can be selected with the drop-down. The COV Increment can be specified for those channels intended for COV reporting by the BACnet client device.

Time and date can be set manually or with the help of a NTP server if access to the Internet is possible. Daylight Savings Time can also be supported. Manually-set time is backed up for seven days through the use of a supercap in the event of power loss. If accessing an NTP server using domain names, make sure the DNS servers are specified in the System Configuration screen.

Separate web pages allow for the configuration of up to 48 web components. Web components provide a means to write and read data to and from Sedona wire sheets without the need of a Workbench tool. A web component configured as a wire sheet input can have its input range restricted to minimum and maximum values eliminating the need to add limit detection within the wire sheet logic. Web components are ideal for simplified control logic configuration.

### Web Components

	Description	Value	Wire Sheet	Min	Max
WC01	Space Temperature (SpcTmp)	77.272514	Output		
WC02	Default Web Component 2	0.000000	Input	0.000000	100.000000
WC03	Default Web Component 3	0.000000	Input	0.000000	100.000000
WC04	Default Web Component 4	0.000000	Input	0.000000	100.000000
WC05	Default Web Component 5	0.000000	Input	0.000000	100.000000
WC06	Default Web Component 6	0.000000	Input	0.000000	100.000000
WC07	Default Web Component 7	0.000000	Input	0.000000	100.000000
WC08	Default Web Component 8	0.000000	Input	0.000000	100.000000

NOTE: A GREEN label indicates that the component has been placed on the wire sheet.

**CONTEMPORARY CONTROLS®**

4

DS-BASC220-AB1

### Virtual Points

Space Temperature Zone 1 VT01 <input type="text" value="83.187"/> <input type="checkbox"/>	Occupied State VT09 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 17 VT17 <input type="text" value="0.000"/> <input type="checkbox"/>
Cooling Runtime in Hrs VT02 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 10 VT10 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 18 VT18 <input type="text" value="0.000"/> <input type="checkbox"/>
Virtual Point 3 VT03 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 11 VT11 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 19 VT19 <input type="text" value="0.000"/> <input type="checkbox"/>
Virtual Point 4 VT04 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 12 VT12 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 20 VT20 <input type="text" value="0.000"/> <input type="checkbox"/>
Virtual Point 5 VT05 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 13 VT13 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 21 VT21 <input type="text" value="0.000"/> <input type="checkbox"/>
Virtual Point 6 VT06 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 14 VT14 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 22 VT22 <input type="text" value="0.000"/> <input type="checkbox"/>
Virtual Point 7 VT07 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 15 VT15 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 23 VT23 <input type="text" value="0.000"/> <input type="checkbox"/>
Virtual Point 8 VT08 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 16 VT16 <input type="text" value="0.000"/> <input type="checkbox"/>	Virtual Point 24 VT24 <input type="text" value="0.000"/> <input type="checkbox"/>

Auto Refresh OFF

NOTES:

1. A GREEN label means that the virtual point has been placed on the wire sheet. The label hover text indicates if the point is configured as "Read from Wire Sheet" or "Write to Wire Sheet"
2. Values for virtual points VT01-VT08 are kept in persistent memory and will remain unchanged through resets and power cycles.

The 24 virtual points are viewable from a separate web page.

### System Status

Firmware Revision <input type="text" value="3.1.23"/>	MAC Address <input type="text" value="00:50:DB:01:6E:50"/>	Available Memory <input type="text" value="25456"/>
--	---	--

#### System Message Log

```

BAScontrol22 : 3.1.23 : May 23 2017 : 08:58:06
Free memory: 98520
Watchdog timer enabled
Refreshing chn_data.xml...done
Low memory limit= 8192
Creating object name and instance mappings...done
Reading binary object data file...done
IP Addr: 10.0.13.10
IP Mask: 255.255.240.0
IP Gate: 10.0.0.1
Start Responder...OK

bacnet-ip : 3.1.23 : May 23 2017 : 08:57:48
SVM starting; 48136 bytes free
Running SVM in platform mode
Sedona VM 1.2.28
buildDate: May 23 2017 08:58:03
endian: little
blockSize: 4
refSize: 4
Network initialized
RTC Time: Thu Jun 1 09:05:30 2017
    
```


The System Status page provides information on the controller.

## Powered by a Sedona Virtual Machine — for Implementing Control

The BAScontrol22 incorporates Sedona Virtual Machine (SVM) technology developed by Tridium. Using established Tridium tools such as Niagara Workbench AX, a system integrator can develop a control application using Workbench’s powerful drag-and-drop visual programming methodology. Once developed, the program remains stored in the BAScontrol22 and executes by way of the SVM. The application can run standalone in the BAScontrol22 or it can interact with a program in a Tridium JACE supervisory controller over Ethernet. The number of potential applications is only limited by the imagination of the system integrator.

The BAScontrol22 includes Tridium’s Sedona 1.2 kits of components — and Contemporary Controls’ product-specific and non-product-specific kits. The BAScontrol22 IO Kit components provide 22 physical points, virtual points and four retentive counters. The BAScontrol22 Web Kit has 48 components that share data with web pages. Input components receive data from hosted web pages. Output components send data to hosted web pages. The Contemporary Controls’ Function kit provides additional components for increased flexibility.

**The free Sedona Application Editor, Workbench AX, or a third-party Sedona tool can be used to program Sedona applications running on the BAScontrol 22.**



**The BAScontrol22’s Sedona Framework logic can operate on its own I/O or its virtual I/O. Also, a network-connected Niagara Framework device can read or modify the operating state of the Sedona Framework function blocks.**

## Contemporary Controls' Developed Sedona Components

### BAScontrol22 I/O Kit BAScontrol22 platform specific components

<b>AO1 – AO4</b>	Analog output – analog voltage output point
<b>BI1 – BI4</b>	Binary input – binary input point
<b>BO1 – BO6</b>	Binary output – binary output point
<b>ScanTim</b>	Scan time monitor – records the min, max and average scan times
<b>UI1 – UI4</b>	Universal input – binary, analog voltage, thermistor, resistance or accumulator
<b>UI5 – UI8</b>	Universal input – binary, analog voltage, thermistor or resistance
<b>UC1 – UC4</b>	Retentive universal counters – up/down retentive counters
<b>VT01 – VT08</b>	Retentive virtual points – share retentive wire sheet data with BACnet/IP clients
<b>VT09 – VT24</b>	Virtual points – share wire sheet data with BACnet/IP clients

### BAScontrol22 Web Kit BAScontrol22 platform specific components

<b>WC01 – WC48</b>	Web components – share wire sheet data with the BAScontrol22 web pages
--------------------	--

### Contemporary Controls Function Kit Common to Sedona 1.2 compliant controllers

<b>Cand2</b>	Two-input Boolean product – two-input AND/NAND gate with complementary outputs
<b>Cand4</b>	Four-input Boolean product – four-input AND/NAND gate with complementary outputs
<b>Cand6</b>	Six-input Boolean product – six-input AND/NAND gate with complementary outputs
<b>Cand8</b>	Eight-input Boolean product – eight-input AND/NAND gate with complementary outputs
<b>Cmt</b>	Comment – comment field up to 64 characters
<b>Cor2</b>	Two-input Boolean sum – two-input OR/NOR gate with complementary outputs
<b>Cor4</b>	Four-input Boolean sum – four-input OR/NOR gate with complementary outputs
<b>Cor6</b>	Six-input Boolean sum – six-input OR/NOR gate with complementary outputs
<b>Cor8</b>	Eight-input Boolean sum – eight-input OR/NOR gate with complementary outputs
<b>CtoF</b>	°C to °F – Celsius to Fahrenheit Temperature Conversion
<b>Dff</b>	“D” Flip-Flop – D-style Edge-triggered Single-bit Storage
<b>FtoC</b>	°F to °C – Fahrenheit to Celsius Temperature Conversion
<b>HLpre</b>	High – Low Preset – defined logical true and false states
<b>PsychrE</b>	Psychrometric Calculator – English Units
<b>PsychrS</b>	Psychrometric Calculator – SI Units
<b>SCLatch</b>	Set/Clear Latch – single-bit level-triggered single-bit data storage

## Tridium’s Sedona 1.2 Components


<p><b>The HVAC Group</b> operations that facilitate control</p>	<p><b>LSeq</b> <b>ReheatSeq</b> <b>Reset</b> <b>Tstat</b></p>	<p>Linear Sequencer — bar graph representation of input value Reheat sequence — linear sequence up to four outputs Reset — output scales an input range between two limits Thermostat — on/off temperature controller</p>
<p><b>The Scheduling Group</b> scheduling operations based upon time of day</p>	<p><b>DailySc</b> <b>DailyS1</b> <b>DateTime</b></p>	<p>Daily Schedule Boolean — two-period Boolean scheduler Daily Schedule Float — two-period float scheduler Time of Day — time, day, month, year</p>
<p><b>The Function Group</b> convenient functions for developing control schemes</p>	<p><b>Cmpr</b> <b>Count</b> <b>Freq</b> <b>Hysteresis</b> <b>IRamp</b> <b>Limiter</b> <b>Linearize</b> <b>LP</b> <b>Ramp</b> <b>SRLatch</b> <b>TickTock</b> <b>UpDn</b></p>	<p>Comparison math — comparison (&lt;=&gt;) of two floats Integer counter — up/down counter with integer output Pulse frequency — calculates the input pulse frequency Hysteresis — setting on/off trip points to an input variable IRamp — generates a repeating triangular wave with an integer output Limiter — Restricts output within upper and lower bounds Linearize — piecewise linearization of a float LP — proportional, integral, derivative (PID) loop controller Ramp — generates a repeating triangular or sawtooth wave with a float output Set/Reset Latch — single-bit data storage Ticking clock — an astable oscillator used as a time base Float counter — up/down counter with float output</p>
<p><b>The Priority Group</b> prioritizing actions of Boolean, Float and Integer variables</p>	<p><b>PrioritizedBool</b> <b>PrioritizedFloat</b> <b>PrioritizedInt</b></p>	<p>Prioritized boolean output — highest of sixteen inputs Prioritized float output — highest of sixteen inputs Prioritized integer output — highest of sixteen inputs</p>
<p><b>The Types Group</b> variable types and conversion between types</p>	<p><b>B2F</b> <b>ConstBool</b> <b>ConstFloat</b> <b>ConstInt</b> <b>F2B</b> <b>F2I</b> <b>I2F</b> <b>L2F</b> <b>WriteBool</b> <b>WriteFloat</b> <b>WriteInt</b></p>	<p>Binary to float encoder — 16-bit binary to float conversion Boolean constant — a predefined Boolean value Float constant — a predefined float variable Integer constant — a predefined integer variable Float to binary decoder — float to 16-bit binary conversion Float to integer — float to integer conversion Integer to float — integer to float conversion Long to float — long integer to float conversion Write Boolean — setting a writable Boolean value Write Float — setting a writable float value Write integer — setting an integer value</p>
<p><b>The Logic Group</b> logical operations using Boolean variables</p>	<p><b>ADemux2</b> <b>And2</b> <b>And4</b> <b>ASW</b> <b>ASW4</b> <b>B2P</b> <b>BSW</b> <b>DemuxI2B4</b> <b>ISW</b> <b>Not</b> <b>Or2</b> <b>Or4</b> <b>Xor</b></p>	<p>Analog Demux — Single-input, two-output analog de-multiplexer Two-input Boolean product — two-input AND gate Four-input Boolean product — four-input AND gate Analog switch — selection between two float variables Analog switch — selection between four floats Binary to pulse — simple mono-stable oscillator (single-shot) Boolean switch — selection between two Boolean variables Four-output Demux — integer to Boolean de-multiplexer Integer switch — selection between two integer variables Not — inverts the state of a Boolean Two-input Boolean sum — two-input OR gate Four-input Boolean sum — four-input OR gate Two-input exclusive Boolean sum — two-input XOR gate</p>
<p><b>The Timing Group</b> time-based components</p>	<p><b>DlyOff</b> <b>DlyOn</b> <b>OneShot</b> <b>Timer</b></p>	<p>Off delay timer — time delay from a “true” to “false” transition of the input On delay timer — time delay from an “false” to “true” transition of the input Single Shot — provides an adjustable pulse width to an input transition Timer — countdown timer</p>
<p><b>The Math Group</b> math-based components</p>	<p><b>Add2</b> <b>Add4</b> <b>Avg10</b> <b>AvgN</b> <b>Div2</b> <b>FloatOffset</b> <b>Max</b> <b>Min</b> <b>MinMax</b> <b>Mul2</b> <b>Mul4</b> <b>Neg</b> <b>Round</b> <b>Sub2</b> <b>Sub4</b> <b>TimeAvg</b></p>	<p>Two-input addition — results in the addition of two floats Four-input addition — results in the addition of four floats Average of 10 — sums the last ten floats while dividing by ten thereby providing a running average Average of N — sums the last N floats while dividing by N thereby providing a running average Divide two — results in the division of two float variables Float offset — float shifted by a fixed amount Maximum selector — selects the greater of two inputs Minimum selector — selects the lesser of two inputs Min/Max detector — records both the maximum and minimum values of a float Multiply two — results in the multiplication of two floats Multiply four — results in the multiplication of four floats Negate — changes the sign of a float Round — rounds a float to the nearest N places Subtract two — results in the subtraction of two floats Subtract four — results in the subtraction of four floats Time average — average value of float over time</p>



# BACnet Protocol Implementation Conformance (PIC) Statement



## BAScontrol22 BACnet/IP Sedona Field Controller



### BACnet Protocol Implementation Conformance Statement (Annex A)

**Date:** August 9, 2016  
**Vendor Name:** Contemporary Controls  
**Product Name:** BAScontrol22  
**Product Model Number:** BASC-22R  
**Applications Software Version:** 1.2.28    **Firmware Revision:** 3.1.2    **BACnet Protocol Revision:** 3  
**Product Description:** BACnet/IP compliant 22-point field controller or remote I/O that allows a direct connection to Ethernet without the need of a BACnet router.

- BACnet Standardized Device Profile (Annex L):**
- BACnet Operator Workstation (B-OWS)
  - BACnet Building Controller (B-BC)
  - BACnet Advanced Application Controller (B-AAC)
  - BACnet Application Specific Controller (B-ASC)
  - BACnet Smart Sensor (B-SS)
  - BACnet Smart Actuator (B-SA)

- List all BACnet Interoperability Building Block Supported (Annex K):**
- DS-RP-B Data Sharing — ReadProperty – B
  - DS-WP-B Data Sharing — WriteProperty – B
  - DS-RPM-B Data Sharing — ReadPropertyMultiple – B
  - DS-COV-B Data Sharing — ChangeOfValue – B
  - DM-DDB-B Device Management — Dynamic Device Binding – B
  - DM-DOB-B Device Management — Dynamic Object Binding – B
  - DM-DCC-B Device Management — Device Communication Control – B
  - DM-TS-B Device Management — Time Synchronization – B

- Segmentation Capability:**
- Able to transmit segmented messages    Window Size:
  - Able to receive segmented messages    Window Size:

**Standard Object Types Supported:**

Object Type Supported	Can Be Created Dynamically	Can Be Deleted Dynamically
Analog Input	No	No
Analog Output	No	No
Analog Value	No	No
Binary Input	No	No
Binary Output	No	No
Binary Value	No	No
Device	No	No

No optional properties are supported.

**Data Link Layer Options:**

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ANSI/ATA 878.1, EIA-485 ARCNET (Clause 8), baud rate(s):
- MS/TP master (Clause 9), baud rate(s):
- MS/TP slave (Clause 9), baud rate(s):
- Point-To-Point, EIA 232 (Clause 10), baud rate(s):
- Point-To-Point, modem, (Clause 10), baud rate(s):
- LonTalk, (Clause 11), medium:
- Other:

**Device Address Binding:**

Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.)  Yes     No

**Networking Options:**


- Router, Clause 6 – List all routing configurations, e.g., ARCNET-Ethernet-MS/TP, etc.
- Annex H, BACnet Tunnelling Router over IP
- BACnet/IP Broadcast Management Device (BBMD)  
Does the BBMD support registrations by Foreign Devices?     Yes     No

**Character Sets Supported:**


- Indicating support for multiple character sets does not imply that they can all be supported simultaneously.
- ANSI X3.4
  - IBM™/Microsoft™ DBCS
  - ISO 8859-1
  - ISO 10646 (UCS-2)
  - ISO 10646 (UCS-4)
  - JIS C 6226

If this product is a communication gateway, describe the types of non-BACnet equipment/network(s) that the gateway supports:  
 No gateway support.

# Wiring Diagram



# Dimensions (all dimensions are in mm)



## Specifications

### Universal Inputs (Points UI1 through UI8)

Configured As	Characteristics
Analog input	0–10 VDC or 0–20 mA (with external resistor). Input impedance 1 MΩ on voltage.
Temperature input	Type II 10 kΩ thermistors: –10° to +190 °F (–23.3° to +87.8°C) Type III 10 kΩ thermistors: –15° to +200 °F (–26.1° to +93.3°C) 20 kΩ thermistors: 15° to 215° F (–9° to +101° C)
Contact closure input	Excitation current 0.5 mA. Open circuit voltage 12 VDC. Sensing threshold 3 VDC (low) and 7 VDC (high). Response time 20 ms.
Pulse input (Points UI1–UI4)	0–10 VDC for active output devices 0–12 VDC for passive devices (configured for internal pull-up resistor) 40 Hz maximum input frequency with 50% duty cycle. Adjustable high and low thresholds.
Resistance	1 kΩ -100 kΩ range

### Binary Inputs (Points BI1 through BI4)

Contact closure	Excitation current 1.2 mA. Open circuit voltage 12 VDC Sensing threshold 3 VDC (low) and 7 VDC (high). Response time 20 ms
-----------------	---

### Analog Outputs (Points AO1 through AO4)

Analog output	0–10 VDC. 10-bit resolution. 4 mA maximum
---------------	---

### Binary Outputs (Points BO1 through BO6) (Class 2 circuits only — requires external power source)

Binary output	Normally open relay contacts. 30VAC/VDC 2A
---------------	--

### Regulatory Compliance

CE Mark; CFR 47, Part 15 Class A; RoHS  
UL 508, C22.2 No. 142-M1987



### Functional

Compliance	IEEE 802.3
Protocols supported	BACnet/IP, Sedona SOX, HTTP and FTP
Data rate	10 Mbps, 100 Mbps
Physical layer	10BASE-T, 100BASE-TX
Cable length	100 m (max)
Port connector	Shielded RJ-45
LED	Green = Link established Flash = Link activity

### Ethernet


### Electrical

Input (DC or AC)	DC	AC
Voltage (V, ± 10%)	24	24
Power	4 W	6 VA
Frequency	N/A	47–63 Hz

## Specifications (continued)

### Environmental/Mechanical

Operating temperature	-40°C to +75°C
Storage temperature	-40°C to +85°C
Relative humidity	10–95%, noncondensing
Protection	IP30
Weight	0.6 lbs. (.27 kg)



### RJ-45 Pin Assignments

10BASE-T/100BASE-TX

Terminal	Usage
1	TD +
2	TD –
3	RD +
6	RD –
Other pins	Not Used

### Electromagnetic Compatibility

Standard	Test Method	Description	Test Levels
EN 55024	EN 61000-4-2	Electrostatic Discharge	6 kV contact & 8 kV air
EN 55024	EN 61000-4-3	Radiated Immunity	10 V/m, 80 MHz to 1 GHz
EN 55024	EN 61000-4-4	Fast Transient Burst	1 kV clamp & 2 kV direct
EN 55024	EN 61000-4-5	Voltage Surge	2 kV L-L & 2 kV L-Earth
EN 55024	EN 61000-4-6	Conducted Immunity	10 Volts (rms)
EN 55024	EN 61000-4-11	Voltage Dips & Interruptions	1 Line Cycle, 1 to 5 s @ 100% dip
EN 55022	CISPR 22	Radiated Emissions	Class A
EN 55022	CISPR 22	Conducted Emissions	Class B
CFR 47, Part 15	ANSI C63-4	Radiated Emissions	Class A

## Ordering Information

Model	Description
BASC-22R	BAScontrol22 BACnet Server 22-Point 6 Relays 2xRJ45 Switch

#### United States

Contemporary Control Systems, Inc.  
2431 Curtiss Street  
Downers Grove, IL 60515  
USA

Tel: +1 630 963 7070  
Fax: +1 630 963 0109

[info@ccontrols.com](mailto:info@ccontrols.com)

#### China

Contemporary Controls (Suzhou) Co. Ltd  
19F, Metropolitan Towers,  
No.199 Shishan Road,  
Suzhou New District,  
215009 China

Tel: +86 512 68095866  
Fax: +86 512 68093760

[info@ccontrols.com.cn](mailto:info@ccontrols.com.cn)

#### United Kingdom

Contemporary Controls Ltd  
14 Bow Court  
Fletchworth Gate  
Coventry CV5 6SP  
United Kingdom

Tel: +44 (0)24 7641 3786  
Fax: +44 (0)24 7641 3923

[ccl.info@ccontrols.com](mailto:ccl.info@ccontrols.com)

#### Germany

Contemporary Controls GmbH  
Fuggerstraße 1 B  
04158 Leipzig  
Germany

Tel: +49 341 520359 0  
Fax: +49 341 520359 16

[ccg.info@ccontrols.com](mailto:ccg.info@ccontrols.com)

[www.ccontrols.com](http://www.ccontrols.com)